

July 22, 2010

IMPORTANT NOTICE

RE: Peel Region's Design and Construction Specifications

Please be advised that effective June 28, 2010 the Region of Peel Watermain Design Criteria and Volume 2.2. Watermain Construction documents have been revised.

The addition of a paragraph under the General sections reads as follows:

Stainless steel bolts and nuts are to be used on all fittings and joint restraints. All metallic fittings, valves and joint restraints must be wrapped end to end with an approved corrosion protection system that includes petrolatum primer (paste), petrolatum moulding mastic, and low temperature petrolatum tape.

All projects awarded following June 28, 2010 will require this standard to be met.

A change order will be issued by the project manager if they wish to implement the new standard in projects currently underway.

Should you have any questions or concerns, please contact me at 905-791-7800 x 3318.

Thank you,



Carol Chaput
Technical and Materials Review Committee Chair

April 6, 2011

Advanced Corrosion Solutions Inc.
#6-68 Healey Road
Bolton, ON
L7E 5A4

Attention: Chris Calder

Dear Mr. Calder:

Re: Product Approval Request: Petro Guard System Reference # 10-32


Your submission and associated literature, specifications and/or sample products for the above noted item has been considered by the Region of Peel's, Technical and Material Review Committee. I am pleased to inform you that the Region of Peel is accepting the **Petro Guard System (paste PP04ST/mastic PM3ST/tape PTLT)** for use in **water/wastewater** applications.

We expect that representatives from Advanced Corrosion Solutions Inc will continue to be available for site visits and provide guidance on installation if required.

The Region of Peel reserves the right at any time to remove approved products from the Public Works Design, Specifications & Procedures Manual, upon poor performance or product failure.

Should you have any questions regarding this matter, you may contact me at (905) 791-7800 extension 3253.

Sincerely,



Denis Lefebvre
Material Review Committee Chair
2 Copper Rd. Brampton,
Ontario L6T 4W5

cc. Rob Ierullo, Material and Review Committee Linear Team Lead

Public Works

**New Product -
Final Summary Report**



General Information

Product Name/ Description (make, model) :		Reference No.	
PETROGUARD (paste PP04ST/mastic PM3ST/tape PTLT)		10-32	
Vendor Name	Final Review Date		
	Yr.	Mo.	Day
Advanced Corrosion Solutions Inc.	2010	02	4

Product Application

<input checked="" type="checkbox"/> Water Linear	<input checked="" type="checkbox"/> Waste Water Linear	<input type="checkbox"/> Waste Management
<input type="checkbox"/> Water Plant and Pumping Station	<input type="checkbox"/> Waste Water Plant Pumping Station	<input type="checkbox"/> Transportation
<input type="checkbox"/> Instrumentation and Control		

Product Assessment

Info Provided by Vendor	<input type="checkbox"/> Product Sample ○ Attached	<input checked="" type="checkbox"/> Product Literature x Attached	<input checked="" type="checkbox"/> Questionnaire x Attached
Does Product Meet Current Specifications for Type of Material			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

Recommendation

Approve Product? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Comments: <ul style="list-style-type: none">- complies with requirements for 3 part corrosion protection system- local distribution in Peel (Bolton)- meet specs of products currently approved such as the Denso System
Reviewed by Rob Ierullo, Ian Cooper

Carpet


Feb 4, 2011

Committee Chair Signature


Public Works

**New Product -
Final Summary Report**

**MATERIALS
REVIEW
COMMITTEE**



**Rick Stroud,
Manager, Water Operations**




**Romano Del Tin
Manager, Wastewater Collection**

Final Approvals

Wastewater

Approve? YES NO N/A (If no, please provide your comments below)

Director's Name: Ric Robertshaw


Signature:  Date: March 2, 2011

Comments: _____

Water

Approve? YES NO N/A (If no, please provide your comments below)

Director's Name: Mark Schiller

Signature:  Date: MM 25, 2011

Comments: _____